

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 4</div>	
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 28-Aug-2001		4. REQUISITION/PURCHASE REQ. NO. W26GLG12006487		5. PROJECT NO.(If applicable)	
6. ISSUED BY CONTRACTING OFFICE (CA/CW) US ARMY ENGR DIST NORFOLK ATTN: CENAO-CT 803 FRONT STREET NORFOLK VA 23510-1096		CODE DACA65		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center;">See Item 6</div>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACA65-01-R-0024	
				X		9B. DATED (SEE ITEM 11) 23-Jul-2001	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u> 1 </u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A.THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B.THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C.THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D.OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Questions The attached questions and answers are provided and are included in the technical requirements of this project. Proposal due date is changed to 07 Sep 2001 at 1400 local time. POC Susan Hurst 757-441-7747 757-441-7183 fax susan.i.hurst@usace.army.mil							
<small>Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.</small>							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 28-Aug-2001	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Changes in Section SF 30

Amendment to Repair Barracks 3100 – Answers to contractor questions

1. Plans call for a 300 KVA transformer, specs indicate 500 KVA. Which governs?

Answer: Provide 300 KVA transformer.

2. Controls for the fan coil units: are they to be stand alone (individually controlled) or standard box, centrally controlled?

Answer: Controls shall be stand alone individually controlled

3. 3. Option 2 is for Horizontal Fan Coil Unit Replacement and now makes a non-phased project into a phased project. The 12 sets of risers (for the Horizontal Fan Coil Units) that are to be installed 2 at a time will add 6 phases to the project. Also, do the 9 Unit Ventilators get replaced under Option 2? How many days will the performance period be extended for Option 2? Please Advise.

Answer: Provide 300 KVA transformer.

4. In the addendum to plans and specifications fan coil units (FCUs) optional bid item 0002 paragraph 1.b. states demolish existing ductwork. Paragraph 1.e. states existing air return shall remain. Please advise.

Answer: The existing air return portion of the ductwork shall remain. Remaining ductwork not associated with the air return shall be removed.

5. Paragraph 1.c states to provide new FCUs directly above room entrance door. Is this the personal room or the bathroom door? Where is soffit to be tied into existing walls?

Answer: Room entrance door is door between corridor and room, not the bathroom door.

6. Reference the requirements for the CQC manager Para 3.4.2.b, the paragraph has two options for the status, but the choice is not indicated. Can the CQC manager be assigned no other duties, or can he be assigned other duties such as superintendent?

Answer: CQC manager shall be “assigned no other duties”. Superintendent may not serve as the CQC manager. Strike through second bracketed phrase in this paragraph.

7. How is the soffit to be tied in to existing walls, Addendum paragraph 1.c?

Answer: Soffit is to enclose dual temp piping which are extensions of the existing pipes to the new FCU. Soffit detail is similar to that shown on sheet A-15 Detail 10 "TYP SOFFIT DETAIL".

8. Do the 9 Unit Ventilators get replaced under Option 0002 (FCU replacement)?

Answer: No, unit ventilators are not included in Option 0002.

9. The 12 sets of risers (for the Horizontal Fan Coil Units) that are to be installed 2 at a time will add 6 phases to the project. Also, do the 9 Unit Ventilators get replaced under Option 2? How many days will the performance period be extended

Answer: The project is not phased, only the shutdown of the FCUs. The entire building will be vacant during construction but the piping loops through this building from another building into another building, so we must isolate it to avoid cutting off the system in another facility. The FCU work will be concurrent with the base bid work - we will not extend the performance period.